

Septic System Unit Design Flows

Use the table below to determine the Daily Design Flow for Other than Single Family Dwellings

Unit Design Flows		
Wastewater Source	Applicable Unit	Sewage Design Flow per Applicable Unit, Gallons Per day
Airport	Passenger (average daily number)	4
	Employee	15
Auto Wash	Facility	Per manufacturer, if consistent with this Chapter
Bar/Lounge	Seat	30
Barber Shop	Chair	35
Beauty Parlor	Chair	100
Bowling Alley (snack bar only)	Lane	75
Camp		
Day camp, no cooking facilities	Camping Unit	30
Campground, overnight, flush toilets	Camping Unit	75
Campground, overnight, flush toilets and shower	Camping Unit	150
Campground, luxury	Person	100-150
Camp, youth, summer or seasonal	Person	50
Church		
Without Kitchen	Person (maximum attendance)	5
With Kitchen	Person (maximum attendance)	7
Country Club	Resident Member	100
	Nonresident Member	10
Dance Hall	Patron	5
Dental Office	Chair	500
Dog Kennel	Animal, maximum occupancy	15
Dwelling		
For determining design flow for sewage treatment facilities under R18-9-B202(A)(9)(a) and sewage collection systems under R18-9-E301(D) and R18-9-B301(K), excluding peaking factor	Person	80
Dwelling		
For on-site wastewater treatment facilities per R18-9-E302 through R18-9-E323:		
Apartment Building		
1 bedroom	Apartment	200
2 bedroom	Apartment	300
3 bedroom	Apartment	400
4 bedroom	Apartment	500
Seasonal or summer dwelling (with recorded seasonal occupancy restriction)	Resident	100
Single Family Dwellings	See R-18-9-A314(D)(1)	See R-18-9-A314(D)(1)
Other than Single Family Dwelling, the greater flow value based on:		
Bedroom Count		
1-2 bedrooms	Bedroom	300
Each bedroom over 2	Bedroom	150
Fixture Count	Fixture Unit	25
Fire Station	Employee	45
Hospital		
All flows	Bed	250
Kitchen waste only	Bed	25
Laundry waste only	Bed	40

Septic System Unit Design Flows

Use the table below to determine the Daily Design Flow for Other than Single Family Dwellings

Unit Design Flows (cont.)		
Wastewater Source	Applicable Unit	Sewage Design Flow Per Applicable Unit, Gallons Per Day
Hotel/Motel		
Without kitchen	Bed (2 person)	50
With kitchen	Bed (2 person)	60
Industrial Facility		
Without showers	Employee	25
With showers	Employee	35
Cafeteria, add	Employee	5
Institutions		
Resident	Person	75
Nursing home	Person	125
Rest home	Person	125
Laundry		
Self service	Wash cycle	50
Commercial	Washing machine	Per manufacturer, if consistent with this Chapter
Office Building	Employee	20
Park (temporary use)		
Picnic, with showers, flush toilets	Parking space	40
Picnic, with flush toilets only	Parking space	20
Recreational vehicle, no water or sewer connections	Vehicle space	75
Recreational vehicle, with water and sewer connections	Vehicle space	100
Mobile home/Trailer	Space	250
Restaurant/Cafeteria	Employee	20
With toilet, add	Customer	7
Kitchen waste, add	Meal	6
Garbage disposal, add	Meal	1
Cocktail lounge, add	Customer	2
Kitchen waste disposal service, add	Meal	2
Restroom, public	Toilet	200
School		
Staff and office	Person	20
Elementary, add	Student	15
Middle and High, add	Student	20
with gym and showers, add	Student	5
With cafeteria, add	Student	3
Boarding, total flow	Person	100
Service Station with toilets		
First bay		1000
Each additional bay		500
Shopping Center, no food or laundry	Square foot of retail space	0.1
Store	Employee	20
Public restroom, add	Square foot of retail space	0.1
Swimming Pool, public	Person	10
Theater		
Indoor	Seat	5
Drive-in	Car space	10